## **High Penetration PV Impact Analysis**

Soorya Kuloor CTO, Advanced Grid Analytics Landis+Gyr



A National Town Meeting


1

# **DER Impact**



A National Town Meeting

- Impact on voltages across the system
- Reverse power flow
- Voltage flickers and fluctuations
- Impact on regulating equipment operations
- Impact on fault currents
- Impact on protection schemes



# **PV Hosting Capacity**



A National Town Meeting

- Maximum hosting with no adverse impact
- Hosting capacity levels vary:
  - Feeder and feeder characteristics
  - Locations within a feeder
  - PV penetration types: distributed, centralized
- Approximate to very detailed analysis
- Detailed analysis requires very accurate and detailed distribution and PV models
- Modifications to a feeder may increase hosting capacity

## High Penetration PV Impact Analysis




A National Town Meeting

- Determine the impact of existing or short term forecasted PV
- Selected 'candidate' substations for analysis
- Selected impact at 50%, 100%, 150%, and 200% of feeder load (April 14<sup>th</sup>, peak irradiance)
- Used combined distribution + sub-transmission models
- Distributed PV pattern
- Midpoint PV pattern
- Endpoint PV pattern
- Feeder breaking point analysis





A National Town Meeting








A National Town Meeting

GridSummit.org



## Voltage Fluctuation: SUBZ18 with 200% PV Penetration

6

## **Breaking Point Analysis**



#### A National Town Meeting

### GridSummit.org

### **Breaking point PV generation for substation SUBW20**

Feeder	Distributed PV (MW)	Midpoint PV (MW)	Endpoint PV (MW)
W201201	4.5	2.2	3
W201202	4.32	2.7	3

## **Breaking point PV generation for substation SUBX12**

Feeder	Distributed PV (MW)	Midpoint PV (MW)	Endpoint PV (MW)
X121201	6.5	3.3	3.8
X121202	4.3	3.6	3.6
X121203	2.5	1.63	1.7
X121204	5.03	2.94	3.35
X121205	4.66	3.39	4.23
X121206	3.75	3.48	3.48

### **Breaking point PV generation for substation SUBY12**

Feeder	Distributed PV (MW)	Midpoint PV (MW)	Endpoint PV (MW)
Y121201	3.27	2.45	2.45
Y121202	1.5	2.05	2.05

## **Breaking point PV generation for substation SUBZ18**

Feeder	Distributed PV (MW)	Midpoint PV (MW)	Endpoint PV (MW)
Z181201	1.54	4.05	3.47
Z181202	2.55	2.83	2.83
Z181203	4.91	3.44	2.94

## Takeaways



- As the DER penetration gets to higher levels it is critical to analyze their impact on the electric system.
- The hosting capacity varies from substation to substation, feeder to feeder, location to location, and also penetration patterns.
- Upgrading few assets and setpoints pushed out the breaking point.
- Detailed location-based hosting capacity analysis may be the best way to define what the true hosting capacity of the system.